

INDOOR AIR QUALITY AND ENERGY EFFICIENCY IN MULTI-APARTMENT BUILDINGS BEFORE AND AFTER RENOVATION

Ilze Dimdiņa¹, Ēriks Krūmiņš², Arturs Lešinskis^{1,2}, Laimdota Šnīdere³, Viktors Zagorskis¹

¹Riga Technical University, Riga, Latvia.

²Latvia University of Agriculture, Jelgava, Latvia.

³Ltd Kaimiņiem.lv, Riga, Latvia.

Abstract

Previous experience shows that renovation of ventilation system is not a typical component of renovation of multi-apartment buildings (MABs) in Latvia. As a consequence, rooms are not ventilated enough and indoor air quality (IAQ) is reduced. This, in turn, leads to progression of the so called sick building syndrome (SBS). IAQ measures in 13 unrenovated MABs shows that CO₂ concentration in 19 of the examined 30 apartments was ≥ 1000 , indicating insufficient ventilation [2].

We present an ongoing project which aims at monitoring IAQ in MABs before and after renovation. We collect measures of indoor air microclimate parameters in 8 (eventually 12) apartments of 5 MABs in Riga, during the heating season of 2010/2011. The measures are collected in two types of standard construction buildings, the so called project type 464 and project type 602, in three and two buildings of each type, where one is renovated and the other is not renovated. Now in 6 apartments of three type 464 buildings (on the first, middle and top floor) and in 2 apartments of two type 602 building (top floor), sensors of air temperature, relative humidity, CO₂ concentration level, and air flow velocity are located to find the average value of IAQ parameters, and to make calculations of indoor air exchange in each apartment. At the same time, outdoor air temperature and relative humidity are measured. The total number of measured parameters is 55 (eventually planned till 98). The measurements are made every minute, and the paper presents data for the duration of 1 to 3 months. The results of the measures make it possible to find and to compare IAQ parameters and energy efficiency in MABs before and after the renovation.

Keywords: CO₂, energy efficiency, indoor air quality, renovation, multi-apartment buildings

1 Introduction

The study was carried out in the frameworks of Baltic Sea Transnational Cooperation Programme 2007-2013, within the project “Energy Efficient and Integrated Urban Planning (UrbEnergy)”, which involved development of an internet portal for on-line monitoring of indoor climate and consumption parameters of renovated and not renovated buildings in Latvia.

The project objective was to identify the microclimate problems in residential buildings before and after renovation, develop recommendations for residential indoor climate and energy efficiency, to test the practical effect of upgrades aimed at indoor air quality improvement, to draw public attention to residential indoor climate problems, to promote civil education and the progress of high-quality renovation of residential buildings.

2 Methods

2.1 Project buildings and apartments

For the project, 5 MABs in Riga were selected, in two types of standard residential buildings. Three of the buildings were of the so called project type 464 (5 floors, 3 staircases, 45 apartments in

each building), and two were of the so called project type 602 (9 floors, 2 staircases, 72 apartments in each building). Because the ownership of MAB apartments in Latvia is typically individual (each apartment has a separate owner), measurements in all the selected apartments had to be agreed with the apartment owners. Because such agreement was not reached in some cases, the planned microclimate monitoring was not realised in three apartments in one of the non-renovated 464-series building, but identical apartments were used in two nearby buildings. In addition, the total number of planned measurements (98 measurement points in 12 apartments) was not achieved because of various technical problems (for example, sealed exhaust ducts) and human factors. As a result, not all monitoring data were fully secured from all measurement points, and in some cases the missing data have been imputed by using indicators from the corresponding measurement point in another, equivalent building within the project. In such cases, the methodology of calculations is explained in the notes to the corresponding results table.

Standard 464-series MAB description [5]: construction year starting from 1961, five (5) floors, sectional type (with a staircase in the middle of each section), with basements and technical space on the attic level, with loggias or balconies; outer wall: 300 mm thick lightweight concrete panels, on outer corners of the balcony and stair area up to 420 mm thick lightweight concrete panels; windows and balcony doors: double glazing in wooden frames.

Renovation upgrades of the 464-series building in year 2008 [3]: attic insulation with ecowool (200 mm); facade insulation with rock wool (100 mm); basement insulation with extruded foam (100 mm), common areas window and door replacement to double-glazed windows in PVC frames, installation of thermostats and heat meters (allocators) on each radiator.

The two unrenovated MABs 464-N1 and 464-N2 had the North oriented end-walls insulated, correspondingly in year 2007 and 2005. The schematic layout and photo (S end-wall, W facade with loggias) of the renovated 464-series building (464-R) and the two non-renovated buildings (464-N1 and 464-N2) are depicted in Figure 1.



Figure 1. 464.series MAB photo and schematic location (renovated: 464-R; not renovated: 464-N1 and 464-N2)

Standard 602-series MAB description [5]: construction year starting from 1967, 6 to 9 floors, sectional type (with a staircase in the middle of each section), with basements and technical space on the attic level, with loggias; external walls: 200 mm (facade walls) and 330 mm (end-wall) lightweight concrete panels; windows and loggia doors with double glazing in wooden frames.

Renovation upgrades of the 602-series MAB in year 2001 [7]: window replacement to double-glazed windows in PVC frames, insulation of walls with 80 mm mineral wool, basement ceiling with 60 mm mineral wool, the top floor covering with a 140 mm mineral wool boards, changing the heating system from a one pipe to a two-pipe heating system, providing individual heat consumption control (thermostats) and accounting (allocators) facilities in each room, upgrading of heating

substation, heating distribution pipes insulation, staircase repair.

The schematic layout and photo of the renovated 602-series (602-R) and non-renovated (602-N) MAB (NW front with the entrance in staircase, SE facade with loggias) are depicted in Figure 2.



Figure 2. 602.series MAB photo and schematic location (renovated: 602-R; not renovated: 602-N)

Apartments for IAQ parameter measurements were chosen, taking into account their location within the building. Individual upgrades in the apartments are:

- 464-R/middle (3) floor - extractor fan in the kitchen and in the combined sanitary facility;

- 464-R/top (5) floor - extractor hood in the kitchen, glassed loggia, combined sanitary facility;
- 464-N2/first (1) floor - recirculating hood in the kitchen;
- 464-N2/middle (4) floor - double-glazed windows in PVC frames, glassed loggia;
- 464-N1/top (5) floor - S end-wall insulated from inside (2004), new radiators (2009), extractor fan in the kitchen and in the combined sanitary facility;
- 602-R/top (9) floor and 602-N/top (9) floor – no data.

The IAQ parameters are measured in 3 apartments (on the first, middle and top floor) of two non-renovated type-464 buildings (464-N1 and 464-N2) and in 3 apartments (on the first, middle and top floor) of one renovated type-464 building (464-R), and in 2 apartments (on the top floor) of one renovated (602-R) and one non-renovated (602-N) type-602 buildings.

2.2 Measuring equipment and measurements

For indoor air parameter measurements, a complex measuring equipment was used, which was set up, in coordination with the apartment's owner, in owner's bedroom (about 1 m above the floor - the working area) or in the kitchen area (about 1 to 1,8 m above the floor). Equipment measurement accuracy (at 25⁰C) is the following: for temperature $\pm 0,5^{\circ}\text{C}$, for relative humidity $\pm 3\%$ of reading value; for CO₂ concentration to ± 40 ppm + 3% of reading value.

For indoor corner temperature measurements a sensor with an accuracy of $\pm 0,3$ K (at 25⁰C) was used. For measurements of exhaust ventilation ducts of the kitchen and lavatory, measuring equipment with an accuracy of: air flow rate $<0,5$ m/s $\pm 7\%$ of reading value (at 25⁰C); temperature $< 0,5^{\circ}\text{C}$ (at 25⁰C, $> 0,5$ m/s) was used.

Outdoor air temperature and relative humidity were measured approximately 1 m above the ground with an accuracy (at 25⁰C) of $\pm 0,3$ K, relative humidity $\pm 3\%$ of reading value (at 30 ... 70% r.m.), $\pm 5\%$ of reading value (at 10 ... 30% r.m. and 70 ... 90% r.m.), $\pm 10\%$ of reading value (at 5 ... 10% r.m. and 90 ... 95% r.m.).

The planned reading period was 1 minute. If a reading was not made due to the technical reasons, the point value in the chart does not appear for the respective period. If the reading is performed, but the measuring equipment "has not provided an answer", value is recorded outside of the measuring range, allowing it to be ignored during the data processing (details of data collection - see Section 2.3). At the present time, the total number of simultaneously measured parameters is 55. In each of 8 project apartments air temperature, relative humidity and CO₂ concentration level in bedroom or kitchen (Table 1) are measured; in 7 project apartments air temperature and air flow velocity in two exhaust ventilation ducts are measured; in 1 project apartment air temperature at the exterior corner is measured; outdoor air temperature, and relative humidity are measured.

2.3 Data extraction and processing

Equipment that participated in the course of data collection [1]:

- controller - provides instantaneous measurements of temperature, relative humidity, carbon dioxide concentration and air flow rate of the object and object points;
- server (hardware and software) for data acquisition and processing - set up as a real physical IBM PC-type device which operates based on the Linux type environment, the server regularly communicates with the existing controllers, surveying the current (instantaneous) data values (data collected at 1 min intervals);

There are regular communication sessions taking place between the server and the controllers, during which data are obtained from the controllers and transferred to the data processing module. Physical or transport-level disturbances are recorded in files.

Program modules ensure the data analysis by performing the following functions:

- separate the controller data from possible interference, which does not include physical or transport-level disturbance categories;
- make the data format adjustment and rounding of data values: temperature - accuracy of 0,1⁰C, relative humidity - accuracy of 1%, CO₂ concentration - 0,001%, air flow rate – 0,1 m/s.

2.4 Thermal energy consumption calculation

The input of district heating system of each MAB is equipped with an individual building heating substation enabled to count the total heat consumption for heating and hot water heating. The methodologies used to calculate data on the building heat consumption and distribution of heating and hot water among the apartments depended on the building maintenance manager. In one building (464-series renovated building 464-R) apartment owners had created their own association, and all the other buildings (464-N1, 464-N2, 602-R, 602-N) were managed by a municipality-owned maintenance company. In the building managed by apartment owners association, the methodology was approved by the apartment owners meeting in accordance with the procedure prescribed by law. The methodology used by the municipality maintenance company has been determined by Riga City Council [6]. Calculations are carried out once a month. The accounting policies and calculations described below are based on information received from the particular building manager.

The methodology for calculating of thermal heating in the renovated 464-series MAB (464-R) (1):

$$Q_H = Q - Q_{hw} = Q - (V_{hw} * T_{hw} / T) \quad (1)$$

where Q_H – heat consumption for heating buildings [MWh];

Q – the total thermal energy consumption for heating and hot water delivered to the building [MWh];

Q_{hw} – heat consumption for hot water heating in the building [MWh];

V_{hw} – the total hot water consumption in the building (the sum of the individual monthly hot water meter reading amount; the study's calculations assumed a constant average of 145 m³ of hot water consumption per building per month) [m³];

T_{hw} – hot water heating rate (the operator's calculations assumed a constant amount of 2,75 LVL/m³ in the 2010/2011 heating season, according to the actual average costs in the summer of 2010) [LVL/m³];

T – heating rate (variable depending on the primary fuel (in the particular case - natural gas) prices and tax changes, heat supply in Riga in all project buildings is provided by the JSC “Rīgas Siltums”) [LVL/MWh].

The buildings total heat consumption Q_H is calculated and distributed between apartments according to the following scheme: 60% based on the heating square meters S_H and 40% based on individual heating (allocator) readings. All the allocator reading data processing and calculations are performed by a service company in accordance with the approved methodology, and taking into account the housing situation and other factors.

In the renovated 602-series (602-R) and non-renovated 464-series (464-N1, 464-N2) and 602-series (602-N) MABs thermal heating calculations are performed on the basis of Riga municipality building regulations [6], under which the (2):

$$Q'_H = Q - Q'_{hw} - Q_c = Q - (V_{hw} * T'_{hw} / T) - q_c * n \quad (2)$$

where Q'_H – heat consumption for heating buildings [MWh];

Q'_{hw} – heat consumption for hot water heating in the building [MWh];

Q_c – heat consumption for hot water circulation within the building [MWh];

T'_{hw} – hot water heating rate [LVL/m³];

$q_c = 0,1$ MWh/apartments – heat consumption for ensuring the hot water circulation per apartment [MWh];

n – number of apartments in MAB.

In the renovated 602-series (602-R) MAB thermal energy for heating is counted individually in each apartment, so the buildings total heat consumption Q'_H is calculated and distributed among the apartments according to the following scheme: 30% on the basis of heating square meters S_H and 70% on the basis of individual heating (allocator) readings. All the allocator reading data processing and calculations are performed by a service company in accordance with the approved methodology, and taking into account the housing situation and other factors.

In the non-renovated buildings, where individual heat metering in apartments is not provided, the buildings total heat consumption Q'_H is calculated and distributed among the apartments on the basis of heating square meters S_H .

This study uses data about building and apartment thermal energy consumption for heating and hot water in accordance with information provided by the maintenance manager and heat supplier. After the project and the data collection will be completed, the data will be cleaned up and reanalyzed in line with the LVS EN ISO13790 methodology.

2.5 Calculation of air exchange

In accordance with the law [4], the normative exchange of air L_{norm} in an apartment is calculated as:

- minimally secured air vent from the apartment, the sum of all the facilities required airflows: at least $50 \text{ m}^3/\text{h}$ from a combined sanitary facility, at least $25 \text{ m}^3/\text{h}$ from toilet facilities, at least $25 \text{ m}^3/\text{h}$ from a bathroom, at least 60 to $90 \text{ m}^3/\text{h}$ from a kitchen (from a kitchen with an electric oven or with a 2-ring gas stove - minimum of $60 \text{ m}^3/\text{h}$, from a kitchen with 3-ring gas stove - minimum of $75 \text{ m}^3/\text{h}$, from a kitchen with 4-ring gas cooker - at least $90 \text{ m}^3/\text{h}$);
- minimum air supply to be provided in the apartment, the sum of all the facilities required airflows: at least $3 \text{ m}^3/\text{m}^2$ per hour flow to the living areas and bedrooms.

In this study the IAQ measurements and calculations have been made in apartments with more than one living room or bedroom, so the exhaust airflow is assumed to be at least $90 \text{ m}^3/\text{h}$ from the cooking area; the actual data about the type of cooking stove was not collected. Bedroom and living room areas have been assumed to be average, according to the standard project plans; in all building types the apartment ceiling height is assumed to be $2,5 \text{ m}$, whereas the actual measurement or comparison with data from the inventory file has not been done. In the calculations, the largest amount obtained by comparing the required exhaust and supply air quantity for an apartment is assumed to be the air exchange in the apartment.

Air exchange L_{mes} , in accordance with the measurements of airflow speed in the exhaust ventilation channels from kitchen and toilet facilities, has been calculated in the following way (3):

$$L_s = s * 0,9 * v * 3600 \quad (3)$$

where L_s – airflow through the exhaust ventilation channel [m^3/h];

s – area of the exhaust ventilation channel, in all calculations assumed equal to $0,10 * 0,15 = 0,015 \text{ m}^2$;
 $0,9$ – applied correction coefficient for the distribution of airflow speed within the cross-section of the ventilation channel;

v – measurement of the airflow speed [m/s]; 3600 – coefficient for transition from seconds to hours.

3 Results and analysis

Separately results of IAQ measures are presented in Figures 3-7. On abscissa is the period of measures – date or time.




Figure 3. Air velocity in exhaust ventilation channel in kitchen (464 type MAB, outdoor temperature about $-10 \text{ }^\circ\text{C}$)

To reach the normative level of air exchange L_{norm} in apartments with the defined exhaust ventilation channel parameters (see Section 2.5) and to provide airflow exchange of $L_{norm} = 140 \text{ m}^3/\text{h}$ in apartments (with 2 exhaust ventilation channels) of type 464 MAB, the necessary airflow speed is $1,44 \text{ m/s}$. In apartments (with 3 exhaust ventilation channels) of type 602 MAB for $L_{norm} = 165$

m^3/h , the necessary airflow speed is 1,13 m/s. Typical results of measures show that air velocity in exhaust ventilation channels does not exceed 1 m/s, and the ventilation problems increase in upper floors and in renovated MAB without organized supply ventilation – see Fig.3.




Figure 4. Relative humidity in apartments (464 type MAB)




Figure 5. CO₂ concentration level in apartments (464 type MAB, outdoor temperature -5...-10 °C)




Figure 6. Temperature in apartments (464 type MAB)




Figure 7. Temperature difference (464-N2/first floor)

The relative humidity level increases in upper floors and in renovated MAB without organized supply ventilation – see Fig.4. Under specific outdoor climate conditions, excessively dry indoor air is a problem with good ventilation without humidifying.

CO₂ concentration level in apartments is mostly dependent on habits of the inhabitants. CO₂ concentration level increases in upper floors and in renovated MAB without organized supply ventilation – see Fig.5. Problems are most often created by blocked exhaust ventilation channels.

Temperature measures in different apartments demonstrate the necessity to change the heat consumption in accordance with individual financial capabilities and comfort demands – see Fig.6.

Temperature difference between the corner and the middle of a room in a typical unrenovated MAB exceed 5⁰C – see Fig.7.

The average outdoor temperatures in Riga in 2010: October +6,05⁰C (average by legislation +7,2⁰C); November +3,32⁰C (+2,1⁰C); December -5,70⁰C (-2,3⁰C) – data by Latvian Environment, Geology and Meteorology Centre.

Table 1 presents location of complex measurement equipment in the apartments and thermal energy consumption of MABs and individual heat consumption of apartments.

Table 1: Thermal energy consumption of MABs and apartments and location of the complex measuring equipment

MAB/apartment floor	S_H, m^2	Location of compl.meas.eq.	Parameter, Dimension	X, 2010	XI, 2010	XII, 2010	Total
464-R	2342,91		Q, MWh	17,28	23,06	36,39	76,73
			$Q*1000/S_H,$ kWh/m ²	7	10	16	33
464-R/first	65,01	kitchen, E facade	$Q_H*1000/ S_H,$ kWh/m ²	11	19	23	53
464-R/middle	38,44	kitchen, W facade		3	5	11	19
464-R/top	67,90	bedroom, N end-wall and W facade with glassed loggia		2	5	11	18
464-N2	2342,91*		Q, MWh	30,3	46,51	73,13	149,94
			$Q*1000/S_H,$ kWh/m ²	13	20	31	64
464-N2/first	65,65	bedroom, S end-wall and W facade with loggia	$Q'_H*1000/ S_H,$ kWh/m ²	6	13	24	43
464-N2/middle	48,13	bedroom, W facade with glassed loggia		6	13	24	43
464-N1	2342,91*		Q, MWh	37,1	51,66	80,22	168,98
			$Q*1000/S_H,$ kWh/m ²	16	22	34	72
464-N1/top	64,59	bedroom, S end-wall and W facade with loggia	$Q'_H*1000/ S_H,$ kWh/m ²	9	15	27	51
602-R	3955,90		Q, MWh	30,61	37,22	62,88	130,71
			$Q*1000/S_H,$ kWh/m ²	8	9	16	33
602-R/top	60,90	no data	$Q'_H*1000/ S_H,$ kWh/m ²	7	8	21	36
602-N	3932,60		Q, MWh	61,5	77,67	125,2	264,37
			$Q*1000/S_H,$ kWh/m ²	16	20	32	68
602-N/top	60,90*	no data	$Q'_H*1000/ S_H,$ kWh/m ²	no data	no data	no data	no data

* comparison of the data from an inventory file is not done

4 Discussion

Results of indoor air quality measurements confirmed ventilation problems and indicated a reduced level of comfort. To improve the microclimate in MAB, ventilation system must be updated in all apartments [2]. The air permeability difference between a typical unapproved blocked duct is 100% before the dismantling of barriers and 400% after the dismantling of barriers [1].

In the upper floors, the observed accumulated moisture in building constructions is 20...35% higher compared to the lower floors, as well as condensate can be observed in the exterior wall

corners. These are consequences resulting from air exchange level that is 2 to 4 times below the normative.

The average bedroom temperature in renovated buildings is 22...24 °C, at the outdoor temperature range between -5 °C and +5° C. The average temperature in non-renovated buildings is 22...24 °C, with 15 °C observed in the corners. But lowering of temperature is precluded by the risk of creating condensate in the corners. It is not possible to reach the temperature of 25 °C in the bathroom at apartment dwellers' preferred time; the actual temperature is 21...22 °C [1].

Temperature measures in different apartments demonstrate the necessity to change the heat consumption according to individual financial capabilities and comfort demands. The thermal energy for heating is reduced by about 50% in renovated MABs. Activities that can increase energy efficiency of buildings, for example, heat insulation of buildings, must be carried out in a complex with all of the engineering system restoration, improvement, or modernization.

The current paper presents intermediate results of an ongoing project. The heating season of 2010/2011 ended on April 21, 2011 but the IAQ measurements in the project buildings will continue till December 1, 2011. After this date, the full project results analyzed in line with the LVS EN ISO13790 methodology will be reported.

5 Acknowledgments

The authors would like to thank the apartment owners of the Project buildings for allowing to perform measurements. Thanks to Vilis Krūmiņš, engineer of Ltd Kaimiņiem.lv.

Research is realized with financial support to I.Dimdiņa from JSC Latvijas gāze.

6 References

1. Caune O.; Dimdiņa I.; Krūmiņš V.; Kupča L.; Stirna G.; Šnīdere L. (Kaimiņiem.lv Ltd.). (2010) *Portāla izveide, datu pieejamība, iekštelpu klimata parametru un patēriņa datu mērījumu veikšana, uzkrāto datu veida un apjoma apraksts, portāla uzturēšanas apraksts*, „Development of an internet portal for on-line monitoring of indoor climate and consumption parameters of renovated and not renovated buildings in Latvia” Project report.
2. Dimdiņa I.; Krūmiņš Ē.; Krūmiņš V.; Lešinskis A. and Šnīdere L. (2010) *Results of Living-Room Microclimate Parameter Measures in Multi-Apartment Buildings before Renovation*, Proceedings of the 7th International Conference on Indoor Climate of Buildings, November-December 2010, Reading, Slovakia, ISBN 978 80 89216 37 6, p. 33-40
3. Jermaka V. (2010) *Veiksmīgas renovācijas paraugs Rīgā*, Discussion „Daudzdzīvokļu dzīvojamo ēku renovācijas gaita Rīgā 2010.gadā”, Power Point Presentation (http://www.rea.riga.lv/files/Veiksmigas_renovacijas_paraugs_Riga.pdf), November 2010.
4. LR Ministru kabinets. (2009) *Noteikumi Nr.102 no 03.02.2009., Noteikumi par Latvijas būvnormatīvu LBN 211-08 "Daudzstāvu daudzdzīvokļu dzīvojamie nami"*, Latvian Construction Norms.
5. Pasaules Bankas tehniskā vienība. (2002) *Mājokļu energoefektivitātes pasākumu sagatavošana Latvijā*, Project report.
6. Rīga City Council. (2010) *Instrukcija Nr.9 "Rīgas pašvaldības īpašumā vai pārvaldīšanā esošajās daudzdzīvokļu dzīvojamās mājās patērētās siltumenerģijas sadales un maksas aprēķināšanas kārtība"*, (http://www.rs.lv/lv/htms/norm_dok/dokuments.php?id=44), Latvian Legislation Norms.
7. University of Latvia. (2003) *Dokumentācija par enerģijas taupīšanas pasākumu veikšanu lielpaneļu dzīvojamā mājā (Ozolciema ielā 46/3) Rīgā*, „Energie Initiative Riga” Project report.