

Calculation of Sprinkler with Gas Saturation at Automatic Foam Fire-extinguishing Systems

Ihar Kachanau¹, ¹Belarusian National Technical University, Ihar Karpenchuk², Siarhei Pauliukou³, Liudmila Liashenka⁴, ²⁻⁴Institute for Command Engineers of the Ministry of Emergencies of the Republic of Belarus

Abstract. The article provides an example of calculating the elements of the sprinkler at automatic foam fire-extinguishing systems. There is Venturi tube at the core of the sprinkler. There are holes in the narrowest section for gas saturation of the extinguishing agent in data Venturi tube. This design allows the sprinkler to increase the effectiveness of fire-extinguishing foam due to its gas saturation, for example, the calculation of the hydrodynamic characteristics of the sprinkler taken universal foam. Data foam is approved for use in the Republic of Belarus. Injector elements are confuser, narrow (constriction) section and diffuser. To reduce losses, an injector inlet diameter is assumed to be the diameter of the output distribution pipe. This technique can be applied to the hydraulic design of automatic foam fire-extinguishing systems.

Keywords: Automatic fire-extinguishing systems, diffuser, dispersion, foam, gas saturation, injector.

I. INTRODUCTION

It is considered that the best foam would be one that has a significant resistance and plentiful water, or low expansion foam and fine-meshed, evenly distributes the bubbles in the layer of foam [1], [2]. The degree of dispersion of the foam depends on the conditions of its production, including the characteristics of the sprinkler or nozzles [3], [4]. The effectiveness of foam (increasing multiplicity and dispersion of the foam) can be improved by means of gas saturation of fire-extinguishing agent. In [5], [6], the authors investigated the fluid mechanics in the sprinklers. Gas saturation is in a narrow section of the injector-sprinkler performed by the type of Venturi tube. As a result, a mathematical model of one-dimensional motion of a gas-liquid mixture has been obtained in the diffuser injector. The solution of this model allows determining the pressure loss in the injector, its geometric characteristics and hydrodynamic parameters [7].

II. GENERAL REGULATIONS

Theoretical Basis of the Calculation of the Elements of the Injector

The calculation should be carried out in the fluid. Injector elements are confuser, narrow (constriction) section and diffuser.

In order to reduce the pressure loss on the initial diameter of the inlet confuser, we accept the diameter of distribution pipe:

$$D_c = D_p. \quad (1)$$

where:

D_p – the diameter of distribution pipe;

D_c – the diameter of confuser.

According to [8], we can plot the cone angle (convergence) by a factor of resistance confuser:

$$\xi = f\left(\alpha_c, \frac{l_c}{d_0}\right), \quad (2)$$

where:

ξ – the drag coefficient of the confuser;

α_c – the cone angle of the confuser;

l_c – the confuser length;

d_0 – the diameter of the narrow section.

The cone angle of the confuser is accepted in the range of 15^0 – 40^0 .

Pressure loss in the confuser is determined using the Weisbach equation:

$$\Delta p_c = \xi_c \rho \frac{v_0^2}{2}, \quad (2)$$

where:

ρ – the density of the extinguishing fluid (foaming agent);

v_0 – the velocity in the narrow section of the injector.

$$v_0 = \frac{4Q}{\pi d_0^2}, \quad (3)$$

where:

Q – the consumption of the extinguishing liquid.

The resistance factor of the confuser can be defined according to [9]:

$$\xi_{conf} = \left(\begin{array}{l} -0.0125n_0^4 + 0.0224n_0^3 - 0.00723n_0^2 + \\ + 0.004444n_0 - 0.00745 \end{array} \right) \times \left(\alpha_p^3 - 2\pi\alpha_p^2 - 10\alpha_p \right), \quad (4)$$

where:

n_0 – the degree of the narrowing part of confuser,

$$n_0 = \left(\frac{d_0}{D_c} \right)^2; \quad (5)$$

$$\alpha_p = 0.01745 \alpha_c. \quad (6)$$

For the final calculation of the confuser to find the value for the diameter of the narrow section of the injector, write the equation of Bernoulli for the inlet and the narrow section of confuser without specific energy provisions of sections because its value is disproportionately low compared to the rest of the equation:

$$p_i + \rho \frac{v_i^2}{2} = p_0 + \rho \frac{v_0^2}{2} + \Delta p_c, \quad (7)$$

where:

p_i – the pressure at the inlet to the injector;
 v_i – the velocity of the fluid at the inlet of the injector;
 p_0 – the pressure in the narrow section.

Transform the equation in terms of:

$$v_i = v_0 \left(\frac{d_0}{D_i} \right)^2 \quad (8)$$

and (5) from (8) after the transformations the diameter of the narrow section can be expressed:

$$d_0 = \sqrt[4]{\frac{8Q^2 \rho}{\pi^2 [p_i - p_0 - \Delta p_c]}}. \quad (9)$$

In the first approximation, calculation of the injector flow path due to the complexity of the process should be done by successive approximations [13]. The diameter of the narrow section can be determined without taking into account the pressure loss in the confuser or $\Delta p_c = 0$:

$$d_0 = \sqrt[4]{\frac{8\rho Q^2}{\pi^2 (p_i - p_0)}}. \quad (10)$$

The next step is to calculate the narrow section in terms of providing the necessary multiplicity of foam. To provide the necessary multiplicity of foam, the flow of air will be:

$$Q_{air} = Q(K-1). \quad (11)$$

where:

K – the multiplicity of foam (given multiplicity).

Considering the flow of air as the outflow through a small hole in a thin wall, a well-known formula can be written [10]:

$$Q_{air} = \mu S_{air} \sqrt{\frac{2\Delta p_{air}}{\rho_{air}}}, \quad (12)$$

where:

μ – the discharge coefficient of small holes $\mu = 0.62$ [6];
 Δp_{air} – the differential pressure between the outside air pressure and vacuum pressure in the narrow section of the injector;

ρ_{air} – density of air, because the fire suppression system in a building is assumed to be 1.29 kg/m^3 ;

S_{air} – the total cross-sectional area of holes for suction (supply) of air flotation given multiplicity,

$$S_{air} = \frac{n_{air} \pi d_{air}^2}{4}, \quad (13)$$

where:

n_{air} – the number of holes for air;

d_{air} – the diameter of holes for air.

Thus, the diameter of the holes for air will be:

$$d_{air} = 2 \sqrt{\frac{Q_{air}}{\pi \mu \sqrt{\frac{2\Delta p_{air}}{\rho_{air}}}}}, \quad (14)$$

or

$$d_{air} = 2 \sqrt{\frac{Q(K-1)}{\pi \mu \sqrt{\frac{2\Delta p_{air}}{\rho_{air}}}}}. \quad (15)$$

The basic calculation is the determination of the diffuser injector pressure drop in the flow of two-phase fluid, the density of which is a function of pressure, changing the non-uniform two-phase fluid flow in the diffuser.

In [11], the dependence to determine the pressure drop in the flow of two-phase fluid in the diffuser injector for non-uniform motion:

$$\Delta p = \frac{2\tau}{tg \frac{\alpha_d}{2}} \ln \frac{D}{d_0} + \frac{8\rho_m Q^2}{\pi^2} \left[\frac{\rho^2}{\rho_m^2 \left(2l_d tg \frac{\alpha_d}{2} + d_0 \right)^4} - \frac{1}{d_0^4} \right], \quad (16)$$

where:

D – the diameter of the outlet section of the injector, which may be taken as the diameter of the inlet section of the sprinkler;

$$D = D_{sp.}; \quad (17)$$

τ – the shear stress at the wall of the diffuser;
 α_d – the cone angle of the diffuser;
 $\rho_{mt.}$ – the density of the two-phase aerated fluid in the diffuser;
 l_d – the length of the diffuser.

To determine the density of the two-phase fluid in [11] a formula is written:

$$\rho_{mt.} = \frac{\rho(p + p_{atm.})}{p + Kp_{atm.}}, \quad (18)$$

where:

p – the pressure at the exit of the diffuser;
 $p_{atm.}$ – the atmospheric pressure.

Considering:

$$2l_d \tan \frac{\alpha_d}{2} + d_0 = D = D_{sp.} \quad (19)$$

Equation (18) can be written as follows:

$$\Delta p = \frac{2\tau}{\tan \frac{\alpha_d}{2}} \ln \frac{D}{d_0} + 0,811 \rho_{mt.} Q^2 \left[\frac{\rho^2}{\rho_{mt.}^2 D^4} - \frac{1}{d_0^4} \right]. \quad (20)$$

The shear stress at the wall of the diffuser for a uniform motion is defined as follows [12]:

$$\tau' = \rho_{mt.} v_*^2, \quad (21)$$

where:

v_* – the friction velocity (or the rate of shear stress on the wall), defined as follows [12]:

$$v_* = \frac{v}{5.75 \lg \frac{a}{\Delta} + 8.5}, \quad (22)$$

where:

Δ – the equivalent roughness;
 a – the distance from the wall of the channel to the layer, moving at an average velocity v .

To determine a , using the 'one-seventh' Karman's law [12]:

$$\frac{v}{v_{\max}} = \left(\frac{a}{r} \right)^{\frac{1}{7}}, \quad (23)$$

where:

r – the radius of the channel,

hence:

$$a = \frac{D}{2} \left(\frac{v}{v_{\max}} \right)^7. \quad (24)$$

According to [12]:

$$\frac{v}{v_{\max}} = 0.75 - 0.9. \quad (25)$$

Shear stress on the wall of the cone is equal to [11]:

$$\tau = k\tau', \quad (26)$$

where:

k – the coefficient reflecting the non-uniform motion and depending on the angle of cone diffuser and being equal 0.996^{α_d} [11].

Thus, all elements of the injector are determined and can be calculated for specific values and parameters for the design of automatic foam fire-extinguishing systems [14].

Example of Calculating the Sprinkler with Pre-aeration with Manufacturer's Characteristics

1. Flow of extinguishing agent (foaming agents):

$$Q = 1.06 \text{ l/s} = 1.06 \cdot 10^{-3} \text{ m}^3/\text{s}.$$

2. Required foam:

$$n = 10.$$

3. The pressure at the outlet of the injector taken to be the pressure at the inlet of the sprinkler:

$$p = 1.5 \text{ atm} = 1.5 \cdot 98100 = 147150 \text{ Pa} = 0.147 \text{ MPa}.$$

4. The inlet pressure to the injector taken to be 5 m (0.5 atm) is more than the output of the sprinkler (the first approximation):

$$p_i = p_{out.} + 0.5 = (1.5 + 0.5) \cdot 98100 = 0.1962 \text{ MPa}.$$

5. The density of the extinguishing agent:

$$\rho = 1000 \text{ kg/m}^3.$$

Calculation of the Injector

A. Confuser

Injector inlet diameter equals the diameter of the output distribution pipe:

$$D_c = 16 \text{ mm} = 16 \cdot 10^{-3} \text{ m}.$$

The cone angle confuser $\alpha_c = 25^\circ$.

Specify the pressure drop in the injector (the first approximation):

$$\Delta p = p_i - p = 49050 \text{ Pa (0.5 atm)} = 0.049 \text{ MPa}.$$

Determine the diameter of the narrow section (the first approximation):

$$d_0 = \sqrt[4]{\frac{8 \cdot \rho \cdot Q^2}{\pi^2 \cdot (p_i - p_0)}}.$$

Pressure in the narrow section $p_0 = -0.5 \text{ atm}$.

$$d_0 = \sqrt[4]{\frac{8 \cdot 1000 \cdot (1.06 \cdot 10^{-3})^2}{3.14^2 \cdot (2 - (-0.5)) \cdot 98100}} = 7.8 \cdot 10^{-3} \text{ m}.$$

Velocity in the narrow section of the confuser:

$$v_0 = \frac{4 \cdot Q}{\pi \cdot d_0^2} = \frac{4 \cdot 1.06 \cdot 10^{-3}}{3.14 \cdot (7.8 \cdot 10^{-3})^2} = 22.2 \text{ m/s}.$$

The compression ratio:

$$n_0 = \left(\frac{d_0}{D_c} \right)^2 = \left(\frac{7.8}{16} \right)^2 = 0.24$$

$$\alpha_p = 0.01745 \cdot \alpha_c = 0.01745 \cdot 25 = 0.436.$$

$$\begin{aligned} \zeta_c = & (-0.0125 \cdot n_0^4 + 0.0224 \cdot n_0^3 - 0.00723 \cdot n_0^2 + 0.00444 \cdot n_0 - 0.00745) \cdot (\alpha_p^3 - 2\pi\alpha_p^2 - 10\alpha_p) = \\ & (-0.0125 \cdot 0.24^4 + 0.0224 \cdot 0.24^3 - 0.00723 \cdot 0.24^2 + 0.00444 \cdot 0.24 - \\ & -0.00745) \cdot (0.436^3 - 2 \cdot 3.14 \cdot 0.436^2 - 10 \cdot 0.436) = 0.04 \end{aligned}$$

Losses in confuser are as follows:

$$\begin{aligned} \Delta p_c = & \zeta_c \cdot \rho \cdot \frac{v_0^2}{2} = 0.04 \cdot 1000 \cdot \frac{22.2^2}{2} = \\ & = 9860 \text{ Pa} = 0.00986 \text{ MPa} \end{aligned}$$

B. Calculation of Air

Calculation of air to produce foam with a multiplicity $n = 10$:

$$Q_{air} = Q \cdot (n - 1) = 1.06 \cdot (10 - 1) = 9.54 \cdot 10^{-3} \text{ m}^3/\text{s}.$$

Difference between the atmospheric pressure and absolute pressure is

$$\Delta p_{air} = p_{atm} - p_0^{abs} = 1 - 0.5 = 0.5 \text{ atm} = 0.04905 \text{ MPa}$$

Number of holes accepted to be $m = 6$.

Diameter of holes to provide air:

$$\begin{aligned} d_{air} = & \frac{2}{m} \sqrt{\frac{Q \cdot (n - 1)}{\pi \cdot \mu \cdot \sqrt{\frac{2 \Delta p_{air}}{\rho_{air}}}}} = \frac{2}{6} \cdot \sqrt{\frac{1.06 \cdot (10 - 1) \cdot 10^{-3}}{3.14 \cdot 0.62 \cdot \sqrt{\frac{2 \cdot 49050}{1.29}}}} = \\ & = \frac{2}{6} \cdot \sqrt{\frac{10.8 \cdot 10^{-3}}{1.95 \cdot \sqrt{76047}}} = 1.4 \cdot 10^{-3} \text{ m} = 1.4 \text{ mm}. \end{aligned}$$

C. The Losses in the Diffuser Injector

$$\Delta p_d = \frac{2 \cdot \tau}{\text{tg} \frac{\alpha_d}{2}} \cdot \ln \frac{D}{d_0} + 0.811 \cdot \rho_d \cdot Q^2 \cdot \left[\frac{\rho^2}{\rho_d^2 \cdot D^4} - \frac{1}{d_0^4} \right],$$

Density of the two-phase flow in the diffuser:

$$\rho_d = \frac{\rho \cdot (p + p_{atm})}{p + n \cdot p_{atm}} = \frac{1000 \cdot (1.5 + 1)}{1 + 10 \cdot 1} = 182 \text{ kg/m}^3.$$

The cone angle of the diffuser accepted to be $\alpha_d = 8.5^\circ$.

$$a = r \cdot \left(\frac{v}{v_{\max}} \right)^7,$$

$$\frac{v}{v_{\max}} \text{ taken to be } 0.8.$$

$$a = \frac{16}{2} \cdot (0.8)^7 = 1.68 \cdot 10^{-3} \text{ m}.$$

Dynamic velocity:

$$v_* = \frac{v_{mt}}{5.75 \cdot \lg \frac{a}{\Delta} + 8.5}.$$

Equivalent roughness for non-ferrous metals accepted to be $\Delta = 0.002 \text{ mm} = 2 \cdot 10^{-6} \text{ m}$.

Velocity without gas saturation is

$$v = \frac{4 \cdot Q}{\pi \cdot D^3} = \frac{4 \cdot 1.06 \cdot 10^{-3}}{3.14 \cdot (16 \cdot 10^{-3})^2} = 5.3 \text{ m/s}.$$

Rate of two-phase flow in the output section is

$$v_* = \frac{29}{5.75 \cdot \lg \frac{1.68}{0.002} + 8.5} = 1.14 \text{ m/s}.$$

The shear stress at the wall of the diffuser for a uniform motion is

$$\tau' = \rho_{mi} \cdot v_*^2 = 182 \cdot 1.14^2 = 236 \text{ Pa}$$

Shear stress on the wall of the diffuser is

$$\tau = k \cdot \tau' = 0.967 \cdot 236 = 228 \text{ Pa},$$

where

$$k = 0.996^{\alpha_d} = 0.996^{8.5} = 0.967.$$

Based on the equations above,

$$\Delta p_d = \frac{2 \cdot 228}{8.5} \cdot \ln \frac{16}{7.8} + 0.811 \cdot 182 \cdot (1.06 \cdot 10^{-3})^2 \times \\ \times \left[\frac{1000^2}{182^2 \cdot (16 \cdot 10^{-3})^4} - \frac{1}{(7.8 \cdot 10^{-3})^4} \right] = 4451 + 31510 = 35960 \text{ Pa}.$$

D. Pressure Losses in the Injector

$$\Delta p = \Delta p_c + \Delta p_d = 9860 + 35960 = 45820 \text{ Pa} = 0.47 \text{ atm}.$$

Uncertainty is

$$\eta = \frac{0.5 - 0.47}{0.5} \cdot 100\% = 6\%.$$

E. Required Pressure at the Inlet to the Injector

$$p_{i.} = 1.5 + 0.47 = 1.97 \text{ atm} = 193257 \text{ Pa} = 0.193 \text{ MPa}.$$

F. Dimensions of the Injector

Confuser:

Thus, the authors obtained the calculations of the experimental model of sprinkler pre-aeration of fire extinguishing agent that will allow developing design

$$l_c = \frac{D_c - d_0}{2 \operatorname{tg} \frac{\alpha_c}{2}} = \frac{16 - 7.8}{2 \operatorname{tg} \frac{25}{2}} = 18.5 \text{ mm}.$$

Diffuser:

$$l_d = \frac{D_d - d_0}{2 \operatorname{tg} \frac{\alpha_d}{2}} = \frac{16 - 7.8}{2 \operatorname{tg} \frac{8.5}{2}} = 55.2 \text{ mm}.$$

Injector:

$$l_{inj} = l_c + l_d = 18.5 + 55.2 = 74 \text{ mm}.$$

III.

CONCLUSIONS

Sprinkler and injector design parameters are presented in the tables below:

TABLE I
ESTIMATED PARAMETERS OF SPRINKLER

Parameters of sprinkler	
Flow rate, Q (l/s)	1.06
Inlet diameter, D (mm)	16
Working pressure in front of the sprinkler, P (MPa)	0.15
Required foam	10
Inlet pressure to the injector, P (MPa)	0.19
Density of the extinguishing agent, ρ (kg/m ³)	1000

TABLE II
ESTIMATED PARAMETERS OF INJECTOR

Parameters of injector	
Necessary pressure in front of the injector, P, (MPa)	0.19
Cone angle of the confuser, α_c (°)	25
Inlet section diameter, D (mm)	16
Narrow section diameter, D (mm)	7.8
Number of the holes	6
Diameter of the holes of the diffuser, D (mm)	1.4
Cone angle of the diffuser, α_d (°)	8.5
Outlet section diameter, D (mm)	16
Confuser length, l_c (mm)	18.5
Diffuser length, l_d (mm)	55.2
Injector length, l_{inj} (mm)	74

documentation for the sprinkler with pre-aeration fire extinguishing agent.

REFERENCES

- [1] Bezrodny, I., Giletych, A., Merkulov, V., Molchanov, V. and Shvyrykov, A. *Firefighting oil*. Moscow: VNIPO, 1996, pp. 51-57.
- [2] Petrov, I., Reutt, V. *Extinguish flammable liquids*. Moscow: Minkomunhoz, 1961, pp. 47 - 61.
- [3] Technical code of practice 45-2.02-190-2010 Fire automatic systems of buildings. Minsk: Stroitehnorm, 2011.
- [4] STB 11.16.06-2011/GOST R 51043-2002 System of fire safety standards. automatic water and foam fire fighting systems. Sprinklers, spray nozzles and water mist nozzles. General technical requirements. Test methods. Minsk: Gosstandart, 2011.
- [5] Kachanau, I., Karpenchuk, I., Pauliukou, S. "Movement of liquid mixture in the injector of sprinkler at automatic fire extinguishing systems". *The Scientific Journal of Riga Technical University*, vol. 3, pp. 33-38., December. 2012.
- [6] Kachanau, I., Karpenchuk, I., Pauliukou, S. (2012, Dec). "Mathematical model of two-phase flow in the diffuser injector with pre-aeration foam". *Technosphere Safety Technology* [On-line]. 5(45), Available: www.ipb.mos.ru/ttb. [May 12, 2013].
- [7] Kachanau, I., Karpenchuk, I., Pauliukou, S. "Equations of motion of gas-liquid mixture in the diffuser injector in automatic fire extinguishing systems". *Emergency: education and science*, vol. 7, pp. 43-49. November. 2012.
- [8] Altshul, A. *Hydraulic resistance*. Moscow, Nedra, 1982, p. 224.
- [9] Idelchik, I., Steinberg, M. *Hydraulic resistance. Catalog*, 3rd ed., Moscow, Mechanical engineering, 1992. p. 672.
- [10] Kachanau, I., Ivashchekin, V. *Fluid mechanics. Laboratory training*. Minsk, National Technical University, 2006. p. 66.
- [11] Karpenchuk, I., Pauliukou, S., Parmon, V., Aushev, I. "Theoretical studies of the mechanics of fluid motion in sprinkler with pre-aeration extinguishing agent", presented at the VIth Int. Conf. Engineering Education, Minsk, Belarus, 2012.
- [12] Rabinovich, E. *Hydraulics*. Moscow: Nedra, 1980, pp. 68-77.
- [13] Rausand, M. *Risk Assessment: Theory, Methods, and Applications (Statistics in Practice)*, NJ Wiley, 2011.
- [14] Rasbash, D., Kandola, B., Ramachandran, G., Law, M., Watts, J. *Evaluation of Fire Safety*, WILEY, 2004. <http://dx.doi.org/10.1002/0470020083>

Ihar Kachanau, Doctor of Engineering Sciences, Professor of Mechanics. The scientific degree "Candidate of Technical Sciences" was awarded in 1982; the Doctor of Engineering Sciences – in 2003. He has been engaged in research activities since 1975. He is currently the Head of the Department of Shipbuilding and Hydraulics at the Belarusian National Technical University. He has initiated the establishment of the specialty "Shipbuilding and Technical Operation of Water Transport" in the Republic of Belarus. He has been a scientific advisor of two science degree candidates; currently he is supervising the work of four graduate students. He is the author of 197 scientific papers, including three monographs, 45 inventions.

He is the Chairman of the Board of D 020,503 of the National Technical University. He is the leader of the interim research team to implement the tasks of the State Programme of Research. E-mail: hidrokaf@bntu.by; phone: +375-17-292-76-77, +375-29-387-39-59.

Ihar Karpenchuk, Candidate of Engineering Sciences, Associate Professor of Mechanics. The scientific degree "Candidate of Technical Sciences" was awarded in 1987. He has been engaged in research activities since 1979. His main research interests include the following areas: study of the fluid mechanics and the optimization of the hydrodynamic parameters of the equipment, fire-fighting, forecasting emergencies in water bodies. He has worked out the thesis "Hydro Methods to Improve Welfare, Facilities and Areas in Emergency Situations" to be awarded the degree of "Doctor of Sciences". He is the author of over 200 scientific papers, holds 30 patents and certificates. He was a scientific advisor of three science degree candidates.

He is a member of the Interdepartmental Commission on State Water Policy at the Council of Ministers. He is the leader of the interim research team to implement the two tasks of the State Scientific and Technical Programme and the three tasks of the State Programme of Research. E-mail: asb@kii.gov.by; phone: +375-29-356-46-12.

Siarhei Pauliukou, Postgraduate Student at the Institute for Command Engineers of the Ministry of Emergencies of the Republic of Belarus. Currently he is working on his thesis "Improving the Efficiency of Foam Fire-extinguishing Systems by Aeration of the Working Environment" to obtain the scientific degree "Candidate of Engineering Sciences".

He is currently the Head of the Department of Automatic Security Systems at the Institute for Command Engineers of the Ministry of Emergencies of the Republic of Belarus. He is the author of four papers, for example: S.Y. Pauliukou, S.P. Eroma and V.V. Parmon, "Equations of Motion of Two-phase Flow in the Diffuser-Injector Aerator Gas Saturation in the Extinguishing Agent," in the *VI International Scientific and Practical Conference*, 2012, pp. 224-226.

He is a member of the scientific staff temporarily to implement two tasks of the State Scientific and Technical Programme and the three tasks of the State Programme of Research. E-mail: Pavlukov79@mail.ru; phone: +375-29-697-98-99.

Liudmila Liashenka, Candidate of Physico-mathematical Sciences. She is a Senior Tutor of the Department of Automatic Security Systems, the Institute for Command Engineers of the Ministry of Emergencies of the Republic of Belarus. The scientific degree "Candidate of Physico-mathematical Sciences" was awarded in 2011.

She holds 3 patents and has written more than 54 scientific papers, for example: L.S. Liashenka, V.A. Kuzmitsky, V.V. Parmon, R.R. Asilbeyli "Definition of Hydrodynamic Parameters of Fire-extinguishing Systems in the Presence of Cavitating Elements" in the *III International Scientific and Practical Conference*, 2012, pp. 178-180; V.A. Kuzmitsky, V.V. Parmon, L.S. Liashenka, R.R. Asilbeyli "Cavitation Mode of Operation of the Foam Generator On-line System Type of Sublayer Extinguishing Containers of Petroleum Products" in the *III International Scientific and Practical Conference*, 2012, pp. 170-173.

She is a member of the scientific staff temporarily to implement two tasks of the State Programme of Research. E-mail: sky11@mail.ru; phone: +375-29-323-47-72.